

**Accident Prevention**Date submitted: **Jan-11-26 15:24:58**

Lodge: **Fort Pierce #1520 (SEC)**  
Report Year: **2025**  
Report Period: **Period 3**  
Lodge Chair: **Kevin Eberle**  
Report Submitted by: **Kevin Eberle / KEBERLE157@COMCAST.NET**

Is there information to report for this period? **Yes**

**Accident Summary**

Number of Accidents/Incidents this Quarter: **2**

**11/12/2025 Kitchen employee cut tip of finger with knife. Went to ER for treatment and returned to work.**

Description of Each (Type, Location, Resolution): **11/28/2025 Employee slipped and fell in ballroom and struck right elbow on floor causing a stress fracture. Employee went to urgent care, saw an orthopedic and returned to work. Could find no reason for slippery conditions on floor. Had flooring company out to inspect floor and rebuffed floor as a precaution**

Were Incidents Reported to Gallagher Bassett?: **Yes**

**Inspection Summary**

Monthly Safety Inspections Completed (Yes/No per Month): **Yes - completed for all three months**

Summary of Issues Found and Actions Taken: **Missing blank on fuse block in lighting panel, replaced.  
Three batteries were bad on exit signs and all three signs were replaced.  
One battery on a set of emergency lights was bad and unit was replaced.  
Sensor for smoke detection on ballroom AC unit duct was faulty and was replaced.  
Items were blocking access to the main fire alarm panel and were removed. Area was flagged for no storage in the future.**

Date of Most Recent Lodge Safety Checklist: **December 29, 2025**

**Preventative Measures**

Trainings Conducted (Dates, Type, Attendance): **None**  
Corrective Actions Implemented:

## General Compliance

Alcohol Service Policy  
Reviewed/Updated (Yes/No): **Yes**

Kitchen/Equipment Safety  
Measures Enforced (Yes/No): **Yes**

Trainings Conducted (Dates,  
Type, Attendance):

## Receipts / Images (if applicable)

## Comments / Requests

Support or Resources Needed:

Corrective Actions

Implemented: